



United States Steel Corporation
Clairton Works
400 State Street
Clairton, PA 15025

RECEIVED

February 19, 2016

26 2016

Jim Hagedorn

Air Protection Division

RECEIVED

26 2016

Air Protection Division

Ms. Karen M. Sagel
Allegheny County Health Department
Department of Air Quality
301 Thirty-Ninth Street
Pittsburgh, PA 15201

Subject: USS Reference Number: 16-0059
ACHD Reference Number: 19724
SCOT Plant
USS Clairton Works

Dear Karen M. Sagel:

The attached form terminates the subject incident and satisfies the requirements of paragraph IV.8 of the Title V operating permit #0052 as issued on March 27th 2012.

I certify that based on the information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete. Any questions concerning this matter should be referred to Jonelle S. Scheetz at 412-233-1015.

Sincerely,

Michael S. Rhoads
Plant Manager
Clairton Works

cc: James W. Hagedorn (USEPA)

NOTICE OF PLANNED OUTAGE OF EQUIPMENT
ARTICLE XXI - SECTION 2108.1

1. USS Reference Number: 16-0059 Termination
ACHD Reference Number: 19724
2. Date & Time of Breakdown: Date: 02/18/16 Time: 0700 hours
3. Company Name: U.S. Steel Corporation - USS Clairton Works
4. Specific Equipment Involved or Affected: SCOT Plant
5. BAPC Permit Number (if applicable):
6. Location: Clairton, PA
7. Nature and cause of breakdown: The SCOT Plant will be taken out of service for approximately 4 hours to install an orifice at the 301-B Burner.
8. Identification of Emissions:
 - A. Type(s) (CO, NOX, SO₂, Particulates, Hydrocarbons, etc.)
Elevated H₂S at the incinerator stack, causing increased SO₂ at point of combustion.
 - B. Toxic qualities of each type (including its qualities as an irritant, and its potential for causing illness, disability, or mortality). SO₂ is an eye, nose, and throat irritant.
 - C. Amount of each type emitted (or likely to be emitted).
Light to Moderate
9. Measures taken (or to be taken) to minimize length of breakdown and amount of emissions, including shutdown or curtailment (or why it is impossible or impractical to do so).
The SCOT Plant returned to service upon completion of the maintenance.
10. Facility back in operation - Date: 02/18/16 Time: 1230 hours

Reviewed by *Jonelle S. Scheetz*
Jonelle S. Scheetz
Environmental Control Engineer

Date *2/19/16*
Phone: 412-233-1015